

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 02/अंप प्र०/०२

Dated: 18.08.26

It is certified that an inspection team headed by MANOJ KUMAR, ASSISTANT RESEARCH OFFICER

(Name of Officers with designation) from U.P. JAL NIGAM (RURAL) PHED

inspected the K.P. CONVENT SCHOOL SIKANDRA PRAYAGRAJ

(Name & Address of the school) on 18.08.2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. CHEMICAL TEST/5449/2026-27 dated 18.8.2026

of REGIONAL WATER ANALYSIS LABORATORY, (PHED Lab) certified that
U.P. JAL NIGAM (RURAL), PRAYAGRAJ

the K.P. CONVENT SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 1 YEAR

Signature with Seal: सहायक शोध अधिकारी

Name: MANOJ KUMAR, ASSISTANT RESEARCH OFFICER

Designation: ASSISTANT RESEARCH OFFICER

Name & Address of the Officer/ Department: जल विभाग (ग्राम) प्रयागराज

To

K.P. CONVENT SCHOOL

SIKANDRA PRAYAGRAJ


(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Water Analysis Report
Regional Water Analysis Laboratory,
Khand Karyalaya, U.P. Jal Nigam,(Rural) Tulapur Pani ki Tanki, Jhansi,
Prayagraj - 211019
"Test Report"



Water Analysis Report
Regional Water Analysis Laboratory,
Khand Karyalaya, U.P. Jal Nigam, (Rural) Tulapur Pani ki Tanki, Jhuns,
Prayagraj - 211019
Test Report

Report No- Bacteriological Test/5449/2026-27		Date-18-08-2026		Temperature- 22° c		Humidity- 44%	
Customer details							
Office Name and Address		K. P Convent School, Sikandra, Sikandra, Prayagraj					
Ref Letter No & Date		Contact No.		8808899993			
Basic Details of Sample							
District		Prayagraj		Block		Sahson	
Gram Panchayat				Village		Sikandra	
Habitation				Location		K. P Convent School,	
Type of Source		RO water		Sample No		26085449	
Quantity of Sample		Normal 1000(ml)		Date of S.C.		07-08-2026	
Receiving Date		07-08-2026		S. Collector		Sample not withdrawn by lab	
Ref. Method of Sampling		IS 3025 (Part 1): 1987		Contact No.			
Analysis Start Date		11-08-2026		Analysis Completion date		12-08-2026	
S.No	Analysed parameters	Observed Value	Unit of Measurement	Specification as per IS 10500:2012		Ref. Method of Analysis	
				Acceptable Limit	Permissible Limit		
1	2	3	4	5	6	7	
1	Total Coliform (Bacteria)	0	CFU/100ml.	Shall Not be Detectable 100 ml Sample	0	APHA 24th-2023,9010	
2	E. Coliform	0	CFU/100ml.	Shall Not be Detectable 100 ml Sample	No relaxation	APHA 24th-2023,9010	
3	Free Residual Chlorine (mg/l)	0.1	mg/l	0.2	0.2	IS 3025 (Part-26):2021	
BDL-Below Detection Limit, NT- Not Tested							
Note 1. This certificate refers only to the particular sample(s) submitted for testing. 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory. 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements. 4. Sample will be stored up to 15 days from the date of issue of test reports unless otherwise specified.							
 Report Prepared by				 lab in charge			
Laboratory Contact detail-Email-labprayagraj@gmail.com							

*****END OF THE REPORT*****

